



CERTIFICATE n° 10-042-8/1 SGWA/APIB

Applicant / Manufacturer: Robur S.p.A., IT-24040 Verdellino

Representative / Distributor: Robur S.p.A., IT-24040 Verdellino

Based on the test and certification regulations of the SGWA testing and certification body gas, the report n° 10-042-8/E2 as well as on the statutory provisions for fire protection APIB, the SGWA hereby certifies the following product series:

Product: Heating devices for central heating: Gas fired absorption heat pump

Serial name: GAHP

Types: GAHP A HT S1, GAHP A Indoor GAHP GS HT
GAHP WS, GAHP AR S

Basic test principle: 2009/142/EC, EN 483 (1999), EN 12309-1 (1999)
APIB- fire safety directive "Thermal devices 2015"

Basic certifying principle: EC report n° 163908 (10/08) of Kiwa Italia Spa, IT-San Vendemiano;
Report, n° 10-042-8 (07/10) of the SGWA Certification Body Gas, CH-Schwerzenbach;
Report, n° 05-017-8 (11/05) of the SGWA Certification Body Gas, CH-Schwerzenbach;

Category: II2H3B/P

Classification type: B23, B53 (GAHP AR); B23, B33, B53 (GAHP GS, GAHP WS)
B23, B33, B53, C13, C33, C43, C53, C63, C83 (GAHP A)

Validity: until the **30.06.2020**

Terms:

- Based on the agreement between the SGWA and the APIB of 1.2.1999, the certificate is also valid as **acceptation of fire protection**.
- For additional terms, see under requirements in the SGWA-report, n° 10-042-8/E2 (06/16).

The applicant is therefore allowed to offer these products as SVGW-certified and to use the SVGW conformity label (publication in the gas certification listing, chapter 4.8).



accredited according to:
SN EN ISO/IEC 17065

SWISS GAS AND WATER INDUSTRY ASSOCIATION

Certification body gas

A blue ink signature of Javier Fernandez, consisting of a stylized 'J' followed by several loops and a horizontal line at the end.

Javier Fernandez
Chief

A blue ink signature of Nesimi Öner, featuring a large, flowing 'N' followed by several loops and a horizontal line at the end.

Nesimi Öner
Substitute

Zürich, 24.06.2016

SVGW

Schweizerischer Verein des
Gas- und Wasserfaches
Grütlistrasse 44
CH-8027 Zürich

Zertifizierungsstelle Gas

Schweizerischer Verein des
Gas- und Wasserfaches
Eschenstrasse 10
CH-8603 Schwerzenbach



ZERTIFIKAT Nr. 10-042-8/1 SVGW/VKF

Antragsteller, Hersteller: Robur S.p.A., IT-24040 Verdellino

Vertreter / Vertreiber: Robur S.p.A., IT-24040 Verdellino

Gestützt auf das Prüf- und Zertifizierungsreglement der SVGW Prüf- und Zertifizierungsstelle Gas, auf den Bericht Nr. **10-042-8/E2** sowie auf die Brandschutzvorschriften VKF zertifiziert der SVGW folgende Serienprodukte:

Produkt: Heizapparate für Zentrale-Heizungen: Gas-Absorptions-Wärmepumpe

Stamm-Bezeichnung: GAHP

Modelle/Typen: GAHP A HT S1, GAHP A Indoor GAHP GS HT
GAHP WS, GAHP AR S

Prüfgrundlage: 2009/142/EG, EN 483 (1999), EN 12309-1 (1999)
VKF- Brandschutzrichtlinie, Wärmetechnische Anlagen (2015)

Zertifizierungsgrundlage: Bericht, Nr. 163908 (10/08) der Kiwa Italia Spa, IT-San Vendemiano;
Bericht, Nr. 10-042-8 (07/10) der SVGW Zertifizierungsstelle Gas, CH-Schwerzenbach
Bericht, Nr. 05-017-8 (11/05) der SVGW Zertifizierungsstelle Gas, CH-Schwerzenbach

Kategorie: II2H3B/P

Installationsart: B23, B53 (GAHP AR); B23, B33, B53 (GAHP GS, GAHP WS)
B23, B33, B53, C13, C33, C43, C53, C63, C83 (GAHP A)

Gültigkeit: bis zum **30.06.2020**

Bestimmungen:

- Das Zertifikat gilt aufgrund der Vereinbarung SVGW/VKF vom 1.2.1999 gleichzeitig als **Anerkennungsausweis für den Brandschutz**.
- Weitere Bestimmungen siehe unter Auflagen im SVGW-Bericht 10-042-8/E2 (06/16).

Der Auftraggeber ist somit berechtigt, diese Produkte als SVGW-zertifiziert anzubieten und das SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Gas, Kapitel 4.8).




akkreditiert nach:
SN EN ISO/IEC 17065

SCHWEIZERISCHER VEREIN DES GAS- UND WASSERFACHES

Zertifizierungsstelle Gas


Javier Fernandez
Leiter


Nesimi Öner
Stv. Leiter

Zürich, 24.06.2016